



Government Of West Bengal  
Office Of The Divisional Fire Officer, Alipurduar  
West Bengal Fire & Emergency Services  
Bauxarfidder Road, Alipurduar, Pin:- 736121

Memo no.:IND/WB/FES/20232024/61332

Date: 11-09-2023

**From:**

Divisional Fire Officer, Alipurduar  
West Bengal Fire & Emergency Services

**To:** TECHNO INDIA GROUP PUBLIC SCHOOL,  
TAPSIKHATA, ALIPURDUAR

**Sub:** Renewal Of Fire Safety Certificate,

This is in reference to your application no. 0125191228140086 dated 09-08-2023 regarding the Renewal Of Fire Safety Certificate,

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

- 1) Regular checking, testing and maintenance of fire safety systems/installations are must.
- 2) Good housekeeping to be maintained.
- 3) Regular checking and maintenance of electrical wiring and installation by a licensed Electricians.
- 4) Regular mock fire drill and evacuation drill should be conducted by participation of all and for this purpose a special crew should be formed.
- 5) Certificate shall have to be obtained from this Office on routine basis about the satisfactory performances off all the fire and life safety installations failing which the Fire Safety Certificate shall be revoked as per rule 18 of the W.B. fire Services (Fire Prevention & Fire Safety) Rules, 2003.
- 6) Fire License shall be obtained from this department separately which are attracts section 12 of FS Act.
- 7) This certificate needs to be renewed after 3(three) yrs as per notification subject to ensure safety first and all safety measures should be in working condition at all time failing which this certificate will automatically liable to be cancelled.



- 8) Occupancy of the building shall not be allowed to change without the concurrence of this department.
- 9) Two staircases should be free from any obstruction at all time.

Signature valid

Digitally Signed:  
Name: PRODIP BASKAR  
Date: 08-Aug-2023 10:42:25  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Alipurduar  
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/2023/1332

